

ADDENDUM No. 1

PROJECT: **LIFT STATION #1 DISCHARGE MANHOLE REPLACEMENTS PROJECT**
CLIENT: **VILLAGE OF CASSOPOLIS**
ISSUE DATE: **MAY 3, 2019**

This Addendum No. 1 makes a clarification to the Contract Documents relating to the above referenced project. This Addendum shall be deemed a part of the Contract Documents, and to the extent that the provisions of the other Contract Documents are in conflict herewith, this Addendum shall control.

CLARIFICATIONS:

1. OBIC 1000 protective lining system provided by OBIC LLC is accepted for use to line the proposed replacement manholes and adequately protect against hydrogen sulfide and other forms of corrosion. The OBIC 1000 protective lining system shall be installed per manufacturer specifications and in accordance with the minimum layer thicknesses below.
 1. Poly Urea Adhesion Coat - 50 mils
 2. Polymer Surface Layer - 400 mils
 3. Final Polyurea Armor Layer - 50 mils

The bidder hereby acknowledges receipt of this Addendum No. 1 and shall include a signed copy with their bid.

Company	Date
---------	------

Signature	Title
-----------	-------

Print or Type Name

